

Indiana Department of Natural Resources / Division of Water

Record of Water Well

Reference Number	Driving Directions To Well		Date Completed
54027	Ex. 6 personal privacy		Sep 1, 1989
Owner/Contractor	Name	Address	Telephone
Well Owner	Ex. 6 personal privacy		(317)244-7590
Building Contractor			
Drilling Contractor	JOSEPH HUSER SERVICES INC.	5728 S EMERSON INDPLS, IN 46237	(317)784-4264
Equipment Operator	SHAWN R. COREY	License: 436	
Construction Details			
Well	Use: Home	Drilling method: Rotary	Pump type: Submersible
	Depth: 50.0 ft.	Pump setting depth: 45.0 ft.	Water quality: OK
Casing	Length: 48.0 ft.	Material: PVC	Diameter: 5.00 in.
Screen	Length: 3.0 ft.	Material: SS	Diameter: 4.00 in. Slot Size: .035
Well Capacity Test	Type of test: Air	Test rate: 20.0 gpm for 1.0 hrs.	Bail test rate:
	Drawdown:	Static water level: 18.0 ft.	
Grouting Information	Material: BENTONITE	Depth: 4.0 to 40.0 ft.	
	Installation method: PUMP	Number of bags used: 1.5	
Well Abandonment	Sealing Material:	Depth:	
	Installation method:	Number of bags used:	
Administrative	County: Marion	Township: 15N	Range: 3E
	Section: NE of the NW of the SW of Section 5		Topo map: Indianapolis West
	Field located by: MCBN	On: 1/1/1992	Grant Name:
	Courthouse loc. by:	On:	Grant No.:
	Loc. accpt. w/o ver. by:	On:	
	Subdivision name:	Lot number:	
	Ft W of EL:	Ft N of SL:	Ft E of WL:
	Ground elevation: 716.0	Depth to bedrock:	Ft S of NL:
	UTM Easting: 565841.8		Aquifer elevation: 666.0
		UTM Northing: 4402515.5	
Well Log	Top	Bottom	Formation
	0	7	BR CLAY
	7	11	SANDY CLAY
	11	39	S&G
	39	45	GREY CLAY
	45	50	S&G
Comments	10/18/2005 MC666		

Indiana Department of Natural Resources / Division of Water

Record of Water Well

Reference Number	Driving Directions To Well		Date Completed
54035	Ex. 6 personal privacy		Jan 29, 1981
Owner/Contractor	Name	Address	Telephone
Well Owner	Ex. 6 personal privacy		
Building Contractor			
Drilling Contractor	MILLS PUMP & WELL DRILLING INC	2508 W MICHIGAN ST, INDPLS IN	
Equipment Operator	RUSSELL MILLS	License:	
Construction Details			
Well	Use: Home	Drilling method: Rotary	Pump type:
	Depth: 75.0 ft.	Pump setting depth:	Water quality:
Casing	Length: 72.0 ft.	Material:	Diameter: 4.00 in.
Screen	Length: 3.0 ft.	Material:	Diameter: 4.00 in. Slot Size: 40
Well Capacity Test	Type of test:	Test rate:	Bail test rate: 10.0 gpm for 1.0 hrs.
	Drawdown:	Static water level: 20.0 ft.	
Grouting Information	Material:		Depth:
	Installation method:		Number of bags used:
Well Abandonment	Sealing Material:		Depth:
	Installation method:		Number of bags used:
Administrative	County: Marion	Township: 15N	Range: 3E
	Section: NW of the NE of the SW of Section 5		Topo map: Indianapolis West
	Field located by: MCBN	On: 1/1/1992	Grant Name:
	Courthouse loc. by:	On:	Grant No.:
	Loc. accpt. w/o ver. by: BRUNS	On: 12/21/1982	
	Subdivision name:	Lot number:	
	Ft W of EL:	Ft N of SL:	Ft E of WL:
	Ground elevation: 717.0	Depth to bedrock:	Bedrock elevation:
	UTM Easting: 566010.0		Aquifer elevation: 642.0
		UTM Northing: 4402525.0	
Well Log	Top	Bottom	Formation
	0	1	BLANK
	1	21	CLAY GRAY
	21	70	CLAY BLUE
	70	75	SAND BLUE
Comments			

Indiana Department of Natural Resources / Division of Water

Record of Water Well

Reference Number	Driving Directions To Well		Date Completed
180316			Jan 15, 1981
Owner/Contractor	Name	Address	Telephone
Well Owner	Ex. 6 personal privacy		
Building Contractor			
Drilling Contractor	MATLOCK WELL DRILLING	401 W MORRIS ST	
Equipment Operator	JERRY OAKLEY	License:	
Construction Details			
Well	Use: Home	Drilling method: Rotary	Pump type:
	Depth: 75.0 ft.	Pump setting depth:	Water quality:
Casing	Length: 75.0 ft.	Material:	Diameter: 4.00 in.
Screen	Length: 5.0 ft.	Material:	Diameter: 4.00 in. Slot Size: #6
Well Capacity Test			
	Type of test:	Test rate:	Bail test rate: 5.0 gpm for 1.0 hrs.
	Drawdown:	Static water level: 20.0 ft.	
Grouting Information			
	Material:		Depth:
	Installation method:		Number of bags used:
Well Abandonment			
	Sealing Material:		Depth:
	Installation method:		Number of bags used:
Administrative			
	County: Marion	Township: 15N	Range: 3E
	Section: NW of the SW of Section 5		Topo map: Indianapolis West
	Field located by:	On:	Grant Name:
	Courthouse loc. by:	On:	Grant No.:
	Loc. accpt. w/o ver. by: BRUNS	On: 2/19/1981	
	Subdivision name:	Lot number:	
	Ft W of EL:	Ft N of SL:	Ft E of WL:
	Ground elevation:	Depth to bedrock:	Bedrock elevation:
	UTM Easting:		Ft S of NL:
			Aquifer elevation:
Well Log			
	Top	Bottom	Formation
	0	3	TOPSOIL
	3	10	OVERBURDEN
	10	38	GRAV
	38	75	OVERBURDEN
Comments			

Indiana Department of Natural Resources / Division of Water

Record of Water Well

Reference Number	Driving Directions To Well			Date Completed
180615				Nov 22, 1973
Owner/Contractor	Name	Address	Telephone	
Well Owner	Ex. 6 personal privacy			
Building Contractor				
Drilling Contractor	HAMILTON BROS INC.	4025 ROCKVILLE RD		
Equipment Operator	JOHN OSBORNE	License:		
Construction Details				
Well	Use: Home	Drilling method: Rotary	Pump type:	
	Depth: 57.0 ft.	Pump setting depth:	Water quality:	
Casing	Length: 55.0 ft.	Material:	Diameter: 4.00 in.	
Screen	Length: 2.0 ft.	Material:	Diameter: 4.00 in. Slot Size: .060	
Well Capacity Test				
	Type of test: Pumping	Test rate: 10.0 gpm for 1.0 hrs.	Bail test rate:	
	Drawdown:	Static water level:		
Grouting Information				
	Material:		Depth:	
	Installation method:		Number of bags used:	
Well Abandonment				
	Sealing Material:		Depth:	
	Installation method:		Number of bags used:	
Administrative				
	County: Marion	Township: 15N	Range: 3E	
	Section: SW of the NW of Section 5		Topo map: Indianapolis West	
	Field located by:	On:	Grant Name:	
	Courthouse loc. by:	On:	Grant No.:	
	Loc. accpt. w/o ver. by: SL	On:		
	Subdivision name:	Lot number:		
	Ft W of EL:	Ft N of SL:	Ft E of WL:	Ft S of NL:
	Ground elevation:	Depth to bedrock:	Bedrock elevation:	Aquifer elevation:
	UTM Easting:		UTM Northing:	
Well Log				
	Top	Bottom	Formation	
	0	6	CLAY	
	6	40	S&G	
	40	57	CLAY	
Comments				

Indiana Department of Natural Resources / Division of Water

Record of Water Well

Reference Number	Driving Directions To Well		Date Completed
180630	SPEEDWAY		Sep 22, 1961
Owner/Contractor	Name	Address	Telephone
Well Owner	Ex. 6 personal privacy		
Building Contractor			
Drilling Contractor	MANFORD DILAN	841 W SUMNER AVE	
Equipment Operator	NOLES CREED	License:	
Construction Details			
Well	Use: Home	Drilling method: Cable Tool	Pump type:
	Depth: 35.0 ft.	Pump setting depth:	Water quality:
Casing	Length: 35.0 ft.	Material:	Diameter: 4.50 in.
Screen	Length: 0.5 ft.	Material:	Diameter: 3.00 in. Slot Size: 6
Well Capacity Test	Type of test: Pumping	Test rate: 10.0 gpm for 1.5 hrs.	Bail test rate:
	Drawdown: 0.0 ft.	Static water level: 20.0 ft.	
Grouting Information	Material:		Depth:
	Installation method:		Number of bags used:
Well Abandonment	Sealing Material:		Depth:
	Installation method:		Number of bags used:
Administrative	County: Marion	Township: 15N	Range: 3E
	Section: SE of the SW of the NW of Section 5		Topo map: Indianapolis West
	Field located by:	On:	Grant Name:
	Courthouse loc. by:	On:	Grant No.:
	Loc. acct. w/o ver. by:	On:	
	Subdivision name:	Lot number:	
	Ft W of EL:	Ft N of SL:	Ft E of WL:
	Ground elevation:	Depth to bedrock:	Bedrock elevation:
	UTM Easting:		UTM Northing:
Well Log	Top	Bottom	Formation
	0	5	YEL CLAY
	5	18	SANDY HARDPAN
	18	25	DRY SAND
	25	35	S&G
Comments			

Indiana Department of Natural Resources / Division of Water

Record of Water Well

Reference Number	Driving Directions To Well	Date Completed
298818		Oct 1, 1997

Owner/Contractor	Name	Address	Telephone
Well Owner	Ex. 6 personal privacy		(317)244-9707
Building Contractor			
Drilling Contractor	DEAN WELL DRILLING INC.	841 W JUMNER AVE., INDPLS., IN 46217	(317)787-4146
Equipment Operator	JOHN AUFDERHEIDE	License: 231	

Construction Details

Well	Use: Home	Drilling method: Rotary	Pump type: Submersible
	Depth: 40.0 ft.	Pump setting depth: 35.0 ft.	Water quality: CLEAR
Casing	Length: 38.0 ft.	Material: PVC	Diameter: 5.00 in.
Screen	Length: 2.0 ft.	Material: SS	Diameter: 4.00 in. Slot Size: .040

Well Capacity Test

Type of test: Air	Test rate: 12.0 gpm for 2.0 hrs.	Bail test rate:
Drawdown: 10.0 ft.	Static water level: 24.0 ft.	

Grouting Information

Material: BENT	Depth: 0.0 to 35.0 ft.
Installation method: TREMIE	Number of bags used: 3

Well Abandonment

Sealing Material:	Depth:
Installation method:	Number of bags used:

Administrative

County: Marion	Township: 15N	Range: 3E
Section: 5		Topo map: Indianapolis West
Field located by:	On:	Grant Name:
Courthouse loc. by:	On:	Grant No.:
Loc. accpt. w/o ver. by:	On:	
Subdivision name:	Lot number:	
Ft W of EL:	Ft N of SL:	Ft E of WL:
Ground elevation:	Depth to bedrock:	Bedrock elevation:
UTM Easting:		Ft S of NL:
		Aquifer elevation:
		UTM Northing:

Well Log

Top	Bottom	Formation
0	4	SILTY DK BRN CLAY
4	41	S&G
41	0	SANDY BRN CLAY

Comments